

UST Program Field Notice of Non-compliance

No. 010

The Environmental Protection Agency (EPA) is responsible for the enforcement of underground storage tank (UST) laws that protect human health and the environment. Pursuant to federal regulation at 40 CFR Part 280, during an inspection on

9/21/95

the following items of UST non-compliance were observed at your facility:

1	Description: Monthly reconciliation sheets for Inventory Control (IC) method of tank leak detection not available during inspection	Correction Required: Submit copies to EPA of past 12 months IC reconciliation sheets	Deadline: 10/15/95
2	Description: Depth to tank volume conversion tables only to nearest one inch - nearest 1/8" are required for IC method	Correction Required: Obtain depth to volume tables for nearest 1/8" depths + submit copies to EPA	Deadline: 10/15/95
3	Description: Drop tube for tank #3 indicates about 4' distance between tank floor + btm. of tube - for IC method separation should not be more than 12"	Correction Required: Verify drop tube length of all 3 tanks + replace as necessary to achieve max. 12" separation - Submit copy of workorder/invoices for this work to EPA	Deadline: 10/15/95
4	Description:	Correction Required:	Deadline:

WARNING

The EPA wishes to work cooperatively with you as the owner and/or operator of this facility to resolve the violations(s) listed above at this time. Therefore, no penalty will currently be assessed. However, if you fail to complete the above noted compliance task(s) before the listed deadline(s), you will become subject to citation and/or formal enforcement action. Such enforcement actions mandate compliance and carry monetary penalties as high as \$10,000 for every day of continued violation on each underground tank.

Notify your EPA contact person (listed below) immediately if you are unable to perform the required actions within the specified dates.

EPA Inspector		Facility Information	
Name:	GEOFF KEELER	Name of Facility:	SMITTY'S CONOCO
Office Address:	EPA REGION 10 1200 6th Ave (WP-133) SEATTLE, WA 98101	Facility ID #	A-260087
Phone:	(206) 553-1089	Address:	102 E. TOPPENISH AVE. TOPPENISH, WA 98948
Signature:	Geoff Keeler	Contact:	EDNA GILSTRAP
		Phone:	(509) 865-5909
		Signature:	Edna Gilstrap